

EU DECLARATION OF CONFORMITY TO TYPE AB TİPE UYGUNLUK BEYANI

according to 2016/426/EU Gas Appliances Regulation Annex III.2 EU Declaration of Conformity to Type
2016/426/AB Gaz Yakan Cihazlara Dair Yönetmelik EK III.2 AB Tipe Uygunluk Beyanı (Modül C2)

Number: **2195-GAR-2433001**
Numara:

Owner of Certificate:
Sertifika Sahibi:

ANADOLU RADYANT ISI SİSTEMLERİ SAN. VE TİC. LTD. ŞTİ.
İVEDİK OSB HAS EMEK SAN.SİT. 675 SK. NO:20-22
YENİMAHALLE / ANKARA

Manufacturer:
Üretici:

ANADOLU RADYANT ISI SİSTEMLERİ SAN. VE TİC. LTD. ŞTİ.
İVEDİK OSB HAS EMEK SAN.SİT. 675 SK. NO:20-22
YENİMAHALLE / ANKARA

Products:
Ürünler:

GAS FIRED OVERHEAD LUMINOUS RADIANT HEATERS
GAZ YAKITLI PLAKALI RADYANT ISITICI

Trademark/s:
Ticari Markalar:

SUNRAY

Type/Model:
Tip/Model:

A1 / SRP and MRB Series
A1 / SRPve MRB Serisi

Base of Certificate:
Sertifika Dayanağı:

EU Type Examination Certificate with number 2195CT92 and 14/11/2024
dated Inspection Reports with number GARC2-824012-01-FR-01
2195CT92 no'lu AT Tip İncelemesi Sertifikası ve GARC2-824012-01-FR-01 no'lu, 14/11/2024 tarihli Muayene Raporları

Expiry Date:
Geçerlilik Tarihi:

24/11/2025

Szutest Uygunluk Değerlendirme A.Ş. hereby confirms that the manufacturer of the above mentioned products, has determined, that satisfies the requirements of Regulation 2016/426/EU of The European Parliament and of the Council of 09 March 2016 relating to appliances burning gaseous fuels Annex III.2 Declaration of Conformity to Type.

Szutest Uygunluk Değerlendirme A.Ş., yukarıda bahsi geçen üreticinin, Avrupa Parlamentosu ve Konseyi 09 Mart 2016 tarihli 2016/426/AB Gaz Yakan Cihazlara Dair Yönetmelik EK-III.2 Tipe Uygunluk Beyanı gerekliliklerini yerine getirdiğini onaylar.

Istanbul, 25/11/2024



.....
RUKİYE BALKAN
Genel Müdür Yardımcısı
Deputy General Manager

TİP / MODEL(LER):
TYPE(S)/MODEL(S)

GAS FIRED OVERHEAD LUMINOUS RADIANT HEATERS / GAZ YAKITLI PLAKALI RADYANT ISITICI

Type / Tip	Models / Modeller	Heat Inputs / Anma Isı Girdileri (kW) G20- 20 mbar			Heat Inputs / Anma Isı Girdileri (kW) G30- 29 mbar		
		1. KADEME	2. KADEME	3. KADEME	1. KADEME	2. KADEME	3. KADEME
A1	MRB DESIGN 10 ÇK/TK	-	-	10	-	-	6,5
	SRP 40-1	-	-	60	-	-	60
	SPR 40-2	-	-	60	-	-	60
	SRP 30-1	-	-	45	-	-	45
	SRP 30-2	-	-	45	-	-	45
	SRP 20-1	-	-	30	-	-	30
	SRP 20-2	-	-	30	-	-	30
	SRP 10-1	-	-	15	-	-	15
	SRP 10-2	-	-	15	-	-	15
	SRP 8-1	-	-	20	-	-	20
	SRP 8-2	-	-	20	-	-	20
	SRP 6-1	-	-	15	-	-	15
	SRP 6-2	-	-	15	-	-	15
	SRP 4-1	5	7,5	10	6	7,5	9
	SRP 4-2	-	-	10	-	-	9

Type / Tip	Models / Modeller	Heat Inputs / Anma Isı Girdileri (kW) G20- 20 mbar			Heat Inputs / Anma Isı Girdileri (kW) G30-29 mbar		
		1. KADEME	2. KADEME	3. KADEME	1. KADEME	2. KADEME	3. KADEME
A1	SRP 8-1 ÇK	10	15	20	10	15	20
	SRP 8-2 ÇK	15	15	20	15	15	20
	SRP 6-1 ÇK	6	9	12	7	9	12
	SRP 6-2 ÇK	7,5	12	15	7,5	12	15
	SRP 4-1 ÇK	5	7,5	10	5	7,5	10
	SRP 4-2 ÇK	5	7,5	10	5	7,5	10
	SRP 1*4 ÇKY	6	9	12	7	9	12
	SRP 2*4 ÇKY	12	18	23	12	18	23
	SRP 3*4 ÇKY	17,5	25	35	17,5	25	35
	SRP 4*4 ÇKY	23	34	46	23	34	46
	SRP 1*10 ÇKY	13	20	27	13	20	27
	SRP 2*10 ÇKY	25	37	51	25	37	51
	SRP 1*12 ÇKY	16	24	32	16	24	32
	SRP 2*12 ÇKY	31	46	62	31	46	62
	SRP 2*8 ÇK	19,1	28,5	38,1	19,1	28,5	38,1
	SRP 2*8 TK	-	-	38,1	-	-	38,1
	SRP ART K 7	-	-	7	-	-	7